

## Horizontal Diaphragm Design with Trus Joist® TJI® Joists

With the ever-increasing optimization of I-joist flange dimensions and properties, more focus has been placed on the performance of these products in horizontal diaphragm applications. Weyerhaeuser has performed a significant amount of full-scale horizontal diaphragm testing with Trus Joist® TJI® joists in accordance with ASTM E455 to validate diaphragm performance properties. Based on this testing, Weyerhaeuser has developed the following guidelines when TJI® joists are used as horizontal diaphragm framing members.

### TJI® Joists as Prescriptive (2015 NBCC, Part 9) Diaphragm Framing Members

TJI® joists are permitted as framing members in prescriptive floor and roof diaphragm construction in accordance with the 2015 NBCC, Part 9. When TJI® 110, 210, and 230 are used in floor diaphragm construction, the sheathing must be a minimum thickness of 19/32" and fastened with 8d (0.131" x 2½") nails.

### TJI® Joists as Engineered Diaphragm Framing Members

TJI® joists may be used as framing members in blocked and unblocked diaphragms constructed with wood structural panels and designed using the procedures specified in CSA O86-14 Clause 11.5.2, subject to the limitations in Table 1 and Table 2. The factored shear resistance must be calculated using the equivalent framing member width and specific gravities given by Table 1 and must not exceed the maximum permitted factored shear resistance given by Table 2.

**TABLE 1: TJI® JOISTS ENGINEERED DIAPHRAGM DESIGN INFORMATION**

TJI® Joist Series	Equivalent Framing Member Width (in.)	Equivalent Specific Gravity (SG)	Closest Permitted Nail Spacing <sup>[1]</sup> (in.)		
			6d (0.113" x 2")	8d (0.131" x 2½")	10d (0.148" x 3")
TJI® 110 TJI® 210	1½	0.50	4	4	4
TJI® 230	2½	0.50	4	4	4
TJI® 360 TJI® 560 TJI® 560D	2½	0.50	3	3	4

[1] One row of nails is permitted along each sheathing panel end and edge. When nail spacing is less than 6" on-center, adjacent nails within a row must be offset (staggered). The closest permitted nail spacing given by Table 1 must not be exceeded. Sawn lumber framing members must be used in lieu of TJI® joist framing members where the required fastener spacing is less than the closest permitted nail spacing.

**TABLE 2: TJI® JOISTS MAXIMUM PERMITTED FACTORED SHEAR RESISTANCE (PLF)**

TJI® Joist Series	Blocked	Unblocked Case 1	Unblocked Case 3	Unblocked Case 2, 4 <sup>[1]</sup>
TJI® 110 TJI® 210	650	390	295	250 <sup>[2]</sup>
TJI® 230	730	435	330	280 <sup>[2]</sup>
TJI® 360 TJI® 560 TJI® 560D	1,040	435	330	330

*TJI® joists are intended for dry use applications.*

*Some TJI® joist series may not be available in your region.*

[1] For TJI® 110, 210, and 230, the factored shear resistance calculated in accordance with CSA O86-14 Clause 11.5.2 shall be multiplied by a factor of 0.85 unless sub-floor adhesives, which have been qualified as Class 1/8 in., Type P/O per ASTM D3498-19, are used in combination with mechanical fasteners attachment.

[2] The factored shear resistance may be multiplied by a factor of 1.18 where sub-floor adhesives, which have been qualified as Class 1/8 in., Type P/O per ASTM D3498-19, are used in combination with mechanical fasteners attachment.

***If you have any questions, please contact your Weyerhaeuser representative.***